




**Department of Forestry
and Fire Management**
Office of the State Fire Marshal



ARIZONA STATE FIRE MARSHAL - Wednesday, April 18, 2018 1:54:40 PM (Richard Moreno)

User Name	Richard Moreno
Form Started	4/18/2018 1:54:40 PM
Inspection Date	Wednesday, April 18, 2018
Occupancy Classification	E
Property Usage	School
Fire Alarm Coverage	Full Coverage
Fire Sprinkler Coverage	Full Sprinkler Coverage
Facility Address	4850 W. JEFFERY RD
County	Pima
Contact Phone Number	520 343-8737

DEPUTY FIRE MARSHAL: Richard Moreno: 82



Phone	(520) 334-0788
Type of Inspection	Scheduled
Inspection	Classification
Inspection Results	
Object of Consultation	INVESTIGATION INTO THE QUESTIONING OF THE EXISTING EXTERIOR GATES AT LAWRENCE ELEMENTARY SCHOOL AND PRINCIPAL'S CONCERN REGARDING FIRE CODE COMPLIANCE AND SCHOOL SECURITY.
Determination	IT WAS DETERMINED BY STATE FIRE MARSHAL THE EXTERIOR GATES IN QUESTIONED COULD NOT BE LOCKED DURING SCHOOL HOURS IN ORDER TO COMPLY WITH THE FIRE CODE. IT WAS ALSO NOTED BY UNLOCKING GATES DURING SCHOOL HOURS THE SCHOOL IS NOT SECURED PER TUSD SCHOOL SAFETY GUIDLINES. PER STATE FIRE MARSHAL BY INSTALLING PANIC HARDWARE AND EXPANDED METAL ON EXTERIOR GATES TUSD WOULD COMPLY WITH THE FIRE CODE AND SCHOOL SECURITY. MARK SMITH WAS ADVISED THAT LOCKED GATES VIOLATIONS HAVE BEEN NOTED SEVERAL TIMES DURING INSPECTIONS AT LAWRENCE ELEMENTARY SCHOOL. DURING SITE VISIT EXTERIOR GATES WERE UNLOCKED.
Inspection Time	1.5
Mileage From Office	15.0
Fire Code	THIS INSPECTION WAS CONDUCTED IN COMPLIANCE WITH THE FIRE CODE AND THE TUSD SAFETY PLAN. THE INSPECTION WAS CONDUCTED ON APRIL 18, 2018 AT 10:30 AM. THE INSPECTION WAS CONDUCTED BY STATE FIRE MARSHAL AND THE TUSD SAFETY PLAN. THE INSPECTION WAS CONDUCTED IN COMPLIANCE WITH THE FIRE CODE AND THE TUSD SAFETY PLAN.
Report received by	MARK SMITH, ZULEMA STANBROOK
Send Email To	mark.smith@tbsd.org ZULEMA.STANBROOK@TUSD.ORG
Date	Wednesday, April 18, 2018