

**Emergency Deficiencies Correction Funding Application**

**Initial Submission Date:**

**Application ID:** 21

**Resubmittal Date:** 9/14/2012 4:08:34 PM

Please provide as much of the requested information as possible. SFB staff will assist in developing required information that is not currently available.

**District Name:** Willcox Unified District

**Superintendent:** Dr. Richard Rundhaug

**Contact Person:** Thomas Currin

**Contact Phone Number:** 520-384-8854

**Contact Email:** tom.currin@wusd13.org

**School Site:** Willcox High School

**Buildings:** 9999 School Wide

**Description of Problem**

Please include a detailed description of the issues, as well as a description of and a copy of any professional studies, citations or reports from government entities, recommended solutions, and any cost information or estimates. If additional space is needed, please attach.

Netsian Technologies worked on sighting in the Auditorium reflectors for the fire alarm system over the weekend. After they were complete they went to the office to check the main panel. They found the system off, the circuit breaker was still on and feeding power but the panel was dead. They were unable to provide an estimate without checking their price listings. After the main panel is replaced, they will be able to tell if any other equipment was affected. As of now, we're unable to provide fire protecton to the High School. I will contact the SFB as soon as I have an estimate.

**Project Category:** Special Systems

**Are any of the above-described issues in buildings or part of buildings that are leased to another entity, including a district sponsored charter school?** N

**Available Funding** Was money to address this issue included in your adopted budget for this fiscal year? ?

Current unencumbered building renewal fund balance (Fund 690):	\$0.00
Current fiscal year building renewal expenditures:	\$0.00
Current balance of unrestricted capital:	\$300,000.00

Please outline any associated insurance coverage.

The District has \$300,000 in Capital that must last the balance of the year. We would be unable to donate towards the completion of this replacement.

**Liaison:** Breuer

gbreuer@azsfb.gov

602-542-6139

## Emergency Deficiencies Correction Funding Application

Superintendent Printed Name \_\_\_\_\_

\_\_\_\_\_  
Superintendent Signature

\_\_\_\_\_  
Date