

Current Status: Processing Complete 8/24/2017 9:14:08 AM **Submission ID:** 1085

Initial Submission Date:

Resubmission Date:

District Name: Alhambra Elementary District

Contact Person: Matthew Shields

Contact Phone: 602-336-2079

Contact Email: mattshields@alhambraesd.org

School: R E Simpson School

Site Address: 5330 North 23rd Avenue Phoenix, Arizona 85015

Project Title: Domestic Back-flow Assembly Replacement

Project Detail: Replacement of the the existing 3" Febco 825YD Domestic back-flow assembly Serial Number #1207060558 attached to meter #175585431 located on the East side of the school along the sidewalk. This unit has been repaired multiple times in the past and is an older assembly that is no longer being manufactured and is in poor condition. Requesting that the unit be replaced with a new Febco 860 Assembly due to the poor condition and the age of the Febco 825YD. This includes the City of Phoenix Back-flow Replacement Permit.

Project Date Range: 8/28/2017 **TO** 9/1/2017

Total Project Cost: \$4,386.49 **Adjacent Ways Cost:** \$4,386.49

Board Meeting Date:

Validation Status: No Review Required

Staff Analysis:

Board Decision: