



Glendale Fire Dept (AZ)
6829 N. 58th Drive
Glendale, AZ 85301

Department Violation Notice

February 12, 2019

BICENTENNIAL NORTH SCHOOL
7237 W MISSOURI AV
Glendale, AZ 85303

An inspection of your facility on Feb 12, 2019 revealed the violations listed below.

The conditions identified are contrary to the Code of The City of Glendale (City Code) and must be corrected upon receipt of this notice. Failure to abate hazards and/or correct fire safety deficiencies may result in criminal action and/or criminal citation in accordance with City Code, Article II, section 16.16(b). In an effort to ensure compliance with City Code, follow-up inspection(s) may be conducted until abatement or corrections are made. In accordance with the community development fee schedule, a re-inspection fee will be assessed upon the fourth and subsequent inspection(s).

Violations


504.1 Required access

Note Access gate to facility doesn't meet fire code requirements. It appears the fencing and gates have been modified.



604.4.2 Power supply

Note Computer lab



704.2 Opening protectives

Note Fire /smoke doors have fusible links replaced with springs. Note library . Note picture of fusible link found in hallway.



901.4.6.2 Marking on access doors

Note POV located on the west side of building needs handle and secured.



907.8.1 Maintenance required

Note Panel in alarm and trouble. Alarm was cleared at inspection.



1031.4 Exit signs

Note Exit signs need serviced



Please do not REPLY to this email. Contact your Fire Inspector directly or the Fire Marshals Office at (623) 930-4420.

Handwritten signature of Jeff Ashley.

AJ0961 JEFF ASHLEY
Inspector

Handwritten signature of Manuel Soza.

Manuel Soza