



Jon Totel <jon.totel@onearchitecture.us>

Maricopa HS Modular 20190620

Eddie Rodriguez <Eddie.Rodriguez@maricopa-az.gov>

Wed, May 1, 2019 at 6:33 PM

To: Jon Totel <jon.totel@onearchitecture.us>

Cc: Daranne Tacker <Daranne.Tacker@maricopa-az.gov>, John Storm <John.Storm@maricopa-az.gov>

Hello Jon,

I have approved w/ conditions plans 20190620 on the portal to release the permits. Prior to receive final C of O all stipulations shall be completed. Please have the construction super coordinate opticom specs with fire and provide electrical at both gate locations.

Thank you,

Stipulations;

- 1) Install automatic gates w/ opticom at Hwy 347 & Honeycutt Ave (2).
- 2) Emergency plan -- the architect & school create an emergency plan per IFC section 403 to be approved to satisfy the fire dept.

Eddie Rodriguez

Fire Marshal

City of Maricopa Fire/Medical

p: 520-494-2303

c: 520-251-0024

f: 520-568-1415

eddie.rodriguez@maricopa-az.gov



45654 West Edison Road, Maricopa, Arizona 85139

Fire Admin. Open Monday-Thursday, 7:00 a.m.-5:00 p.m., closed Friday



Maricopa-AZ.gov | eNewsletter | Facebook | Twitter | YouTube | Flickr | Text Alerts

From: Jon Total <jon.total@onearchitecture.us>
Sent: Wednesday, May 1, 2019 11:53 AM
To: Eddie Rodriguez <Eddie.Rodriguez@maricopa-az.gov>
Subject: Re: Maricopa HS Modular 20190620

ATTENTION: This email is from an EXTERNAL source. OUTSIDE the City of Maricopa network. DO NOT CLICK links or open attachments unless you are sure the source, sender, and content of the email is credible.

Hi Eddie,

I just wanted to follow up on a few things. Daranne posted those drawings onto the portal. Do you know when we might have a permit for the on-site?

Also, we want to prepare for running the electrical to the automatic gates. You said it is required at the gate along Hwy 347, so we will do that. You said "most likely" at the 2nd gate off Honeycutt Ave. Can you let me know Yes or No if that one is required to be automatic.

Also, do you have a cut sheet for the automatic gates system we should use?

Thank you,

Jon Total
Project Manager

[Redacted signature]

[Quoted text hidden]