Validation Form SFBADJW-16

Submission ID: 2652 **Current Status:** Resubmitted 7/12/2022 10:09:44 AM

Initial Submission Date: 7/8/2022 **Resubmission Date:** 7/12/2022 **District Name:** Mesa Unified District **Contact Person:** Camille Ashcroft **Contact Phone:** 4804726006

> Contact Email: ciashcroft@mpsaz.org **School:** Hale Elementary School

Site Address: 1425 N. 23rd St., 85213-4018 Project Title: Mesa 11923-01 Hale ADJ WAYS

Project Detail: Remove 16,767 square feet of asphalt and base to a depth of 3 inches. Fine grade

existing base, add moisture, and compact to grade. Pave 16,767 square feet of 1/2 inch MAG asphalt surface course to a finished depth of 3 inches. Install 7 speed

bumps (3 feet wide X 3 inch height to 0 inches on the edge).

7/26/2022 TO 7/27/2022 **Project Date Range:**

Total Project Cost: \$239,242.86 **Adjacent Ways Cost:** \$103,419.51

Board Meeting Date:

Validation Status: Review Pending

Staff Analysis: This is a proposal to remove and replace the asphalt fire/bus lanes and the parking at

this school. This would include striping and signage. The district is asking for adjacent ways funds for the work to the fire/bus lane and the district funds will be used for the parking areas. After reviewing the percentage portion of the adjacent way and that of the parking, SFB Staff agrees that this appropriate use of adjacent was funding.

All required documents are in order.

Board Decision:

PDF Generated: 7/12/2022 10:09:47 AM **Submission ID:** 2652 1 Page: